

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500287891
Report January 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C		DEV agar after 44 ± 4 h at 36 ± 2°C		Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
							KBE/ml	Limit Value 100	KBE/ml	Limit Value 100			
100736363	Drinking water Delivery Tap 1	05.01.2011	09:10	11,5	colorless, clear	0,94	0		0		0	0	0
100736364	Drinking water Delivery Tap 2	05.01.2011	09:12	11,9	colorless, clear	1,02	0		0		0	0	0
100735667	Drinking water Delivery Tap 3	05.01.2011	09:20	11,2	colorless, clear	0,85	0		0		0	0	0
100735668	Drinking water Delivery Tap 4	05.01.2011	10:01	9,9	colorless, clear	0,99	0		0		0	0	0
100735669	Tank vehicle KWW 28, clutch pipe delivery	05.01.2011	10:12	11,8	colorless, clear	0,81	0		0		0	0	0
100735673	Tank vehicle KWW 29, clutch pipe delivery	05.01.2011	10:14	12,0	colorless, clear	1,62	0		0		0	0	0
100735674	Tank vehicle KWW 30, clutch pipe delivery	05.01.2011	09:45	10,7	colorless, clear	1,05	0		0		0	0	0
100735675	Tank vehicle KWW 31, clutch pipe delivery	05.01.2011	09:57	12,9	colorless, clear	0,84	0		0		0	0	0
100735676	Tank vehicle KWW 32, clutch pipe delivery	05.01.2011	10:16	12,3	colorless, clear	0,74	0		0		0	0	0
100735680	Tank vehicle KWW 33, clutch pipe delivery	05.01.2011	09:54	11,5	colorless, clear	0,64	0		0		0	0	0
100735681	Tank vehicle KWW 34, clutch pipe delivery	05.01.2011	09:39	10,2	colorless, clear	0,97	0		0		0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500287891
Report January 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C		DEV agar after 44 ± 4 h at 36 ± 2 °C		Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
							KBE/ml	Limit Value 100	KBE/ml	Limit Value 100			
100735682	Tank vehicle KWW 35, clutch pipe delivery	05.01.2011	09:22	10,6	colorless, clear	1,01	0		0		0	0	0
100735683	Tank vehicle KWW 36, clutch pipe delivery	05.01.2011	09:50	10,7	colorless, clear	0,90	0		0		0	0	0
100735684	Tank vehicle KWW 37, clutch pipe delivery	05.01.2011	09:41	6,4	colorless, clear	0,67	0		0		0	0	0
100735688	Tank vehicle KWW 38, clutch pipe delivery	05.01.2011	09:36	9,2	colorless, clear	0,86	0		0		0	0	0
100735689	Tank vehicle KWW 39, clutch pipe delivery	05.01.2011	09:35	9,4	colorless, clear	0,94	0		0		0	0	0
100735690	Tank vehicle KWW 40, clutch pipe delivery	05.01.2011	09:24	8,3	colorless, clear	0,63	0		0		0	0	0
100735691	Tank vehicle KWW 41, clutch pipe delivery	05.01.2011	09:28	8,2	colorless, clear	0,59	0		0		0	0	2

Assessment:

According to the investigations of the German Drinking Water Regulation the following parameter of the testing samples **100735691**

out of limit value: **Pseudomonas aeruginosa**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, January 12, 2010