

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report June 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C		DEV agar after 44 ± 4 h at 36 ± 2°C		Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
							KBE/ml	Limit Value 100	KBE/ml	Limit Value 100			
1966679	Drinking water Delivery Tap 1	21.06.2011	09:29	17,7	colorless, clear	0,85	0		0		0	0	0
1966680	Drinking water Delivery Tap 2	21.06.2011	09:30	18,2	colorless, clear	0,86	0		0		0	0	0
1966681	Drinking water Delivery Tap 3	21.06.2011	09:40	18,4	colorless, clear	0,62	0		0		0	0	0
1966682	Drinking water Delivery Tap 4	21.06.2011	09:33	18,7	colorless, clear	0,70	0		0		0	0	0
1966685	Tank vehicle KWW 30, clutch pipe delivery	21.06.2011	09:10	18,4	colorless, clear	0,85	0		0		0	0	0
1966686	Tank vehicle KWW 31, clutch pipe delivery	21.06.2011	09:17	18,0	colorless, clear	1,35	0		1		0	0	0
1966687	Tank vehicle KWW 32, clutch pipe delivery	21.06.2011	09:21	18,2	colorless, clear	1,30	0		0		0	0	0
1966688	Tank vehicle KWW 33, clutch pipe delivery	21.06.2011	09:20	17,9	colorless, clear	1,41	0		0		0	0	0
1966689	Tank vehicle KWW 34, clutch pipe delivery	21.06.2011	09:16	18,0	colorless, clear	1,38	0		0		0	0	0
1966690	Tank vehicle KWW 35, clutch pipe delivery	21.06.2011	09:13	18,2	colorless, clear	1,20	0		0		0	0	0
1966691	Tank vehicle KWW 36, clutch pipe delivery	21.06.2011	09:08	17,8	colorless, clear	1,18	0		0		0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report June 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C		DEV agar after 44 ± 4 h at 36 ± 2 °C		Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
							KBE/ml	Limit Value 100	KBE/ml	Limit Value 100			
1966692	Tank vehicle KWW 37, clutch pipe delivery	21.06.2011	09:02	18,4	colorless, clear	1,35	4		2		0	0	0
1966693	Tank vehicle KWW 38, clutch pipe delivery	21.06.2011	08:58	18,2	colorless, clear	1,16	0		0		0	0	0
1966694	Tank vehicle KWW 39, clutch pipe delivery	21.06.2011	09:25	18,2	colorless, clear	1,26	0		0		0	0	0
1966696	Tank vehicle KWW 41, clutch pipe delivery	21.06.2011	08:55	18,2	colorless, clear	1,02	0		0		0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, July 05, 2011
