

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report March 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C		DEV agar after 44 ± 4 h at 36 ± 2°C		Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
							KBE/ml	Limit Value 100	KBE/ml	Limit Value 100			
110113690	Drinking water Delivery Tap 1	23.03.2011	09:51	15,4	colorless, clear	0,64	0		0		0	0	0
110113692	Drinking water Delivery Tap 2	23.03.2011	09:55	15,4	colorless, clear	0,45	0		0		0	0	0
110113693	Drinking water Delivery Tap 3	23.03.2011	10:00	16,4	colorless, clear	0,76	1		1		0	0	0
110113695	Drinking water Delivery Tap 4	23.03.2011	10:04	16,1	colorless, clear	1,46	0		0		0	0	0
110113696	Tank vehicle KWW 28, clutch pipe delivery	23.03.2011	09:45	15,2	colorless, clear	0,71	0		1		0	0	0
110113697	Tank vehicle KWW 29, clutch pipe delivery	23.03.2011	09:30	15,2	colorless, clear	0,73	0		0		0	0	0
110113698	Tank vehicle KWW 30, clutch pipe delivery	23.03.2011	09:24	14,2	colorless, clear	0,69	0		0		0	0	0
110113699	Tank vehicle KWW 31, clutch pipe delivery	23.03.2011	09:48	14,2	colorless, clear	0,70	0		0		0	0	0
110113851	Tank vehicle KWW 33, clutch pipe delivery	23.03.2011	09:20	15,6	colorless, clear	0,65	0		0		0	0	0
110113855	Tank vehicle KWW 35, clutch pipe delivery	23.03.2011	09:41	15,2	colorless, clear	0,70	0		0		0	0	0
110113856	Tank vehicle KWW 36, clutch pipe delivery	23.03.2011	09:34	14,2	colorless, clear	0,68	0		0		0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report March 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2 °C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
110113857	Tank vehicle KWW 37, clutch pipe delivery	23.03.2011	09:36	14,7	colorless, clear	0,60	6	0	0	0	0
110113858	Tank vehicle KWW 38, clutch pipe delivery	23.03.2011	09:32	14,9	colorless, clear	0,57	0	0	0	0	0
110113860	Tank vehicle KWW 40, clutch pipe delivery	23.03.2011	09:39	15,9	colorless, clear	0,68	1	0	0	0	0
110113861	Tank vehicle KWW 41, clutch pipe delivery	23.03.2011	09:26	14,9	colorless, clear	0,78	1	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, march 31, 2011
