

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report May 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2 °C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
110245446	Tank vehicle KWW 33, clutch pipe delivery	10.05.2011	09:12	16,1	colorless, clear	1,40	0	0	0	0	0
110282451	Tank vehicle KWW 32, clutch pipe delivery	10.05.2011	09:15	15,8	colorless, clear	1,70	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, may 20, 2011
