

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report September 2011

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2 °C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
110571572	Tank vehicle KWW 39, clutch pipe delivery	09.09.2011	09:20	19,0	colorless, clear	0,98	0	0	0	0	0
110571573	Tank vehicle KWW 41, clutch pipe delivery	09.09.2011	09:30	19,0	colorless, clear	1,00	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, September 13, 2011
