

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report April 2012

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
120220503	Drinking water Delivery Tap 1	04.04.2012	10:12	14,7	colorless, clear	0,69	0	0	0	0	0
120220504	Drinking water Delivery Tap 2	04.04.2012	10:16	15,1	colorless, clear	0,79	0	0	0	0	0
120220505	Drinking water Delivery Tap 3	04.04.2012	10:18	14,0	colorless, clear	0,45	0	1	0	0	0
120220506	Drinking water Delivery Tap 4	04.04.2012	09:23	14,2	colorless, clear	1,02	0	0	0	0	0
120220507	Tank vehicle KWW 28, clutch pipe delivery	04.04.2012	10:05	14,7	colorless, clear	0,63	0	0	0	0	0
120220509	Tank vehicle KWW 30, clutch pipe delivery	04.04.2012	09:20	14,9	colorless, clear	0,67	0	0	0	0	0
120220510	Tank vehicle KWW 31, clutch pipe delivery	04.04.2012	10:02	15,6	colorless, clear	0,55	0	0	0	0	0
120220511	Tank vehicle KWW 32, clutch pipe delivery	04.04.2012	09:30	14,7	colorless, clear	0,60	0	0	0	0	0
120220512	Tank vehicle KWW 33, clutch pipe delivery	04.04.2012	09:40	14,9	colorless, clear	0,55	0	0	0	0	0
120220513	Tank vehicle KWW 34, clutch pipe delivery	04.04.2012	09:33	16,1	colorless, clear	0,48	0	0	0	0	0
120220514	Tank vehicle KWW 35, clutch pipe delivery	04.04.2012	09:55	14,9	colorless, clear	0,52	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500319580
Report April 2012

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2 °C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
120220515	Tank vehicle KWW 36, clutch pipe delivery	04.04.2012	09:45	15,4	colorless, clear	0,25	0	0	0	0	0
120220517	Tank vehicle KWW 38, clutch pipe delivery	04.04.2012	09:25	14,4	colorless, clear	0,58	1	1	0	0	0
120220518	Tank vehicle KWW 39, clutch pipe delivery	04.04.2012	09:35	14,7	colorless, clear	0,57	0	0	0	0	0
120220519	Tank vehicle KWW 40, clutch pipe delivery	04.04.2012	09:37	14,4	colorless, clear	0,60	0	0	0	0	0
120220520	Tank vehicle KWW 41, clutch pipe delivery	04.04.2012	10:10	14,7	colorless, clear	0,71	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, April 11, 2012