

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles und delivery

Sampling date 05.12.2012

Dienstag, 11. Dezember 2012

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-28 clutch pipe delivery	11,3	7,6	1,87	0	0	0	0	0	0
Tank vehicle KWW-29 clutch pipe delivery	12,6	7,7	1,07	0	0	0	0	0	0
Tank vehicle KWW-30 clutch pipe delivery	13,1	7,7	1,17	0	0	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	13,3	7,7	1,23	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	12,0	7,8	0,95	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	13,8	7,9	1,01	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	11,7	7,8	0,97	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	13,0	7,7	1,07	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	10,4	7,9	1,01	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	11,8	7,7	0,97	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	9,7	7,7	0,65	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	10,7	7,9	1,01	0	1	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	11,6	7,8	0,93	0	3	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	8,8	7,9	0,50	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	13,0	7,6	1,42	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	15,7	7,6	0,30	0	1	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	14,0	7,6	0,55	0	1	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	13,5	7,6	1,34	0	3	0	0	0	0