

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500319580**  
**Report March 2012 - adjusted version**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
120122246	Drinking water Delivery Tap 1	28.03.2012	09:55	14,2	colorless, clear	0,53	0	0	0	0	0
120122247	Drinking water Delivery Tap 2	28.03.2012	09:47	14,2	colorless, clear	0,62	0	0	0	0	0
120122248	Drinking water Delivery Tap 3	28.03.2012	09:58	14,5	colorless, clear	0,74	34	72	0	0	0
120122249	Drinking water Delivery Tap 4	28.03.2012	10:00	14,9	colorless, clear	0,65	0	0	0	0	0
120122250	Tank vehicle KWW 28, clutch pipe delivery	28.03.2012	09:39	15,2	colorless, clear	0,35	0	0	0	0	0
120122253	Tank vehicle KWW 31, clutch pipe delivery	28.03.2012	09:41	15,7	colorless, clear	0,36	0	0	0	0	0
120122254	Tank vehicle KWW 32, clutch pipe delivery	28.03.2012	09:36	17,0	colorless, clear	0,46	0	0	0	0	0
120122255	Tank vehicle KWW 33, clutch pipe delivery	28.03.2012	09:35	14,3	colorless, clear	0,42	0	0	0	0	0
120122256	Tank vehicle KWW 34, clutch pipe delivery	28.03.2012	10:05	15,4	colorless, clear	0,16	0	0	0	0	0
120122257	Tank vehicle KWW 35, clutch pipe delivery	28.03.2012	09:53	16,1	colorless, clear	0,28	0	0	0	0	0
120122258	Tank vehicle KWW 36, clutch pipe delivery	28.03.2012	09:43	15,9	colorless, clear	0,16	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500319580**  
**Report March 2012 - adjusted version**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2 °C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
120122261	Tank vehicle KWW 39, clutch pipe delivery	28.03.2012	09:45	17,3	colorless, clear	0,27	0	0	0	0	0
120122262	Tank vehicle KWW 40, clutch pipe delivery	28.03.2012	09:30	15,0	colorless, clear	0,47	0	0	0	0	0
120122263	Tank vehicle KWW 41, clutch pipe delivery	28.03.2012	09:32	15,5	colorless, clear	0,27	0	0	0	0	<b>3</b>

**Assessment:**

According to the investigations of the German Drinking Water Regulation the following parameter of the testing sample **120122263** out of limit value: **Pseudomonas aeruginosa**

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, April 12, 2012

\_\_\_\_\_