

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste

**Report on the samples being taken by our field service - Your Order No.: BVD-4500319580**  
**Report May 2012**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
120297996	Drinking water Delivery Tap 1	30.05.2012	10:34	19,0	colorless, clear	0,82	3	3	0	0	0
120297997	Drinking water Delivery Tap 2	30.05.2012	10:37	19,4	colorless, clear	0,86	0	0	0	0	0
120297998	Drinking water Delivery Tap 3	30.05.2012	10:43	18,8	colorless, clear	0,87	0	0	0	0	0
120297999	Drinking water Delivery Tap 4	30.05.2012	10:46	18,6	colorless, clear	0,48	0	0	0	0	0
120298000	Tank vehicle KWW 28, clutch pipe delivery	30.05.2012	10:20	22,0	colorless, clear	0,48	0	0	0	0	0
120298051	Tank vehicle KWW 29, clutch pipe delivery	30.05.2012	10:30	20,3	colorless, clear	0,63	0	0	0	0	0
120298052	Tank vehicle KWW 30, clutch pipe delivery	30.05.2012	10:17	19,7	colorless, clear	0,88	0	0	0	0	0
120298053	Tank vehicle KWW 31, clutch pipe delivery	30.05.2012	10:15	19,4	colorless, clear	0,99	1	0	0	0	0
120298054	Tank vehicle KWW 32, clutch pipe delivery	30.05.2012	10:03	20,3	colorless, clear	0,78	0	0	0	0	0
120298055	Tank vehicle KWW 33, clutch pipe delivery	30.05.2012	10:07	19,9	colorless, clear	0,77	0	0	0	0	0
120298056	Tank vehicle KWW 34, clutch pipe delivery	30.05.2012	10:22	20,8	colorless, clear	0,90	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500319580**  
**Report May 2012**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2 °C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2 °C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0
120298058	Tank vehicle KWW 36, clutch pipe delivery	30.05.2012	10:26	20,1	colorless, clear	0,81	0	0	0	0	0
120298060	Tank vehicle KWW 38, clutch pipe delivery	30.05.2012	10:40	21,1	colorless, clear	0,79	0	0	0	0	0
120298061	Tank vehicle KWW 39, clutch pipe delivery	30.05.2012	10:05	19,7	colorless, clear	0,95	0	0	0	0	0
120298062	Tank vehicle KWW 40, clutch pipe delivery	30.05.2012	10:24	20,1	colorless, clear	0,82	0	0	0	0	0
120298063	Tank vehicle KWW 41, clutch pipe delivery	30.05.2012	10:50	20,3	colorless, clear	0,92	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, June 04, 2012