

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500319580**  
**Report October 2012**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
120709604	Drinking water Delivery Tap 1	31.10.2012	10:31	14,7	colorless, clear	0,63	0	2	0	0	0	0
120709605	Drinking water Delivery Tap 2	31.10.2012	10:23	15,7	colorless, clear	0,74	0	0	0	0	0	0
120709606	Drinking water Delivery Tap 3	31.10.2012	10:25	16,6	colorless, clear	0,35	0	1	0	0	0	0
120709607	Drinking water Delivery Tap 4	31.10.2012	10:28	16,4	colorless, clear	0,33	0	0	0	0	0	0
120709609	Tank vehicle KWW 29, clutch pipe delivery	31.10.2012	09:35	15,6	colorless, clear	0,60	0	0	0	0	0	0
120709610	Tank vehicle KWW 30, clutch pipe delivery	31.10.2012	10:07	13,2	colorless, clear	0,52	0	1	0	0	0	0
120709611	Tank vehicle KWW 31, clutch pipe delivery	31.10.2012	09:43	9,6	colorless, clear	0,84	0	<b>550</b>	0	0	1	0
120709612	Tank vehicle KWW 32, clutch pipe delivery	31.10.2012	09:38	14,2	colorless, clear	0,45	0	0	0	0	0	0
120709613	Tank vehicle KWW 33, clutch pipe delivery	31.10.2012	09:40	13,5	colorless, clear	0,56	0	0	0	0	0	0
120709614	Tank vehicle KWW 34, clutch pipe delivery	31.10.2012	09:50	15,6	colorless, clear	0,44	0	0	0	0	0	0
120709615	Tank vehicle KWW 35, clutch pipe delivery	31.10.2012	09:49	14,2	colorless, clear	0,36	0	1	0	0	0	0
120709616	Tank vehicle KWW 36, clutch pipe delivery	31.10.2012	10:12	13,0	colorless, clear	0,46	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500319580  
Report October 2012**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
120709617	Tank vehicle KWW 37, clutch pipe delivery	31.10.2012	10:18	14,2	colorless, clear	0,38	0	0	0	0	0	0
120709621	Tank vehicle KWW 38, clutch pipe delivery	31.10.2012	09:47	15,6	colorless, clear	0,40	0	0	0	0	0	0
120709622	Tank vehicle KWW 39, clutch pipe delivery	31.10.2012	09:45	12,8	colorless, clear	0,46	0	2	0	0	0	0
120709623	Tank vehicle KWW 40, clutch pipe delivery	31.10.2012	10:10	13,7	colorless, clear	0,43	0	0	0	0	0	0

**Assessment:**

According to the investigations of the German Drinking Water Regulation the following parameters of the testing sample **120709611** out of limit value: **KBE at 36 ± 2°C and Pseudomonas aeruginosa**

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, October 6, 2012

\_\_\_\_\_