

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775
Report April 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130259963	Drinking water Delivery Tap 1	24.04.2013	09:58	16,4	colorless, clear	0,67	1	2	0	0	0	0
130259964	Drinking water Delivery Tap 2	24.04.2013	10:02	15,0	colorless, clear	0,86	0	0	0	0	0	0
130259965	Drinking water Delivery Tap 3	24.04.2013	10:09	15,2	colorless, clear	0,76	0	0	0	0	0	0
130259966	Drinking water Delivery Tap 4	24.04.2013	10:20	14,7	colorless, clear	0,73	0	0	0	0	0	0
130259967	Tank vehicle KWW 28, clutch pipe delivery	24.04.2013	09:51	17,1	colorless, clear	0,78	0	1	0	0	0	0
130259968	Tank vehicle KWW 29, clutch pipe delivery	24.04.2013	09:32	16,1	colorless, clear	0,73	0	0	0	0	0	0
130259969	Tank vehicle KWW 30, clutch pipe delivery	24.04.2013	09:21	16,1	colorless, clear	0,32	0	0	0	0	0	0
130259970	Tank vehicle KWW 31, clutch pipe delivery	24.04.2013	09:37	17,8	colorless, clear	0,86	0	0	0	0	0	0
130259971	Tank vehicle KWW 32, clutch pipe delivery	24.04.2013	09:45	15,7	colorless, clear	0,73	0	0	0	0	0	0
130259972	Tank vehicle KWW 33, clutch pipe delivery	24.04.2013	09:18	14,2	colorless, clear	0,69	0	0	0	0	0	0
130259974	Tank vehicle KWW 35, clutch pipe delivery	24.04.2013	09:24	15,7	colorless, clear	0,79	0	0	0	0	0	0
130259975	Tank vehicle KWW 36, clutch pipe delivery	24.04.2013	09:27	15,0	colorless, clear	0,80	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775
Report April 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130259977	Tank vehicle KWW 38, clutch pipe delivery	24.04.2013	09:42	15,4	colorless, clear	0,68	0	0	0	0	0	0
130259978	Tank vehicle KWW 39, clutch pipe delivery	24.04.2013	09:35	16,1	colorless, clear	0,87	0	0	0	0	0	0
130259979	Tank vehicle KWW 40, clutch pipe delivery	24.04.2013	09:13	16,2	colorless, clear	0,83	0	0	0	0	0	0
130259980	Tank vehicle KWW 41, clutch pipe delivery	24.04.2013	09:29	18,0	colorless, clear	0,83	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, April 30, 2013