

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 04.12.2013

Donnerstag, 12. Dezember 2013

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony	colony	Escherichia	Coliforms	Pseudomonas	Enterococcus
				count at 22°C [KBE/ml] limit value 100	count at 36°C [KBE/ml] limit value 100	coli [KBE/100ml] limit value 0	[KBE/100ml] limit value 0	aeruginosa [KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-30 clutch pipe delivery	9,0	7,8	0,68	2	0	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	12,1	7,6	0,79	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	14,4	7,7	0,71	2	2	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	12,3	7,6	0,83	1	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	10,6	7,7	0,85	1	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	10,1	7,8	0,71	1	1	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	13,0	7,9	0,78	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	13,0	7,6	0,90	1	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	11,2	7,8	0,87	2	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,3	7,7	0,82	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	14,0	7,6	0,83	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	8,9	7,7	0,81	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	13,5	7,5	0,97	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	13,6	7,5	0,94	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	13,0	7,5	0,71	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	12,8	7,5	1,27	0	0	0	0	0	0