

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775**  
**Report February 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130084196	Drinking water Delivery Tap 1	27.02.2013	09:48	10,6	colorless, clear	0,69	0	0	0	0	0	0
130084197	Drinking water Delivery Tap 2	27.02.2013	10:01	10,2	colorless, clear	0,86	0	0	0	0	0	0
130084198	Drinking water Delivery Tap 3	27.02.2013	09:51	10,8	colorless, clear	1,12	0	0	0	0	0	0
130084199	Drinking water Delivery Tap 4	27.02.2013	09:45	11,1	colorless, clear	1,45	0	0	0	0	0	0
130084200	Tank vehicle KWW 28, clutch pipe delivery	27.02.2013	09:21	8,3	colorless, clear	0,67	0	0	0	0	0	0
130084201	Tank vehicle KWW 29, clutch pipe delivery	27.02.2013	09:22	8,6	colorless, clear	0,77	0	0	0	0	0	0
130084202	Tank vehicle KWW 30, clutch pipe delivery	27.02.2013	09:39	8,8	colorless, clear	0,61	0	0	0	0	0	0
130084203	Tank vehicle KWW 31, clutch pipe delivery	27.02.2013	09:09	8,6	colorless, clear	0,59	0	0	0	0	0	0
130084204	Tank vehicle KWW 32, clutch pipe delivery	27.02.2013	09:35	10,7	colorless, clear	1,67	0	0	0	0	0	0
130084205	Tank vehicle KWW 33, clutch pipe delivery	27.02.2013	09:27	8,3	colorless, clear	0,69	0	0	0	0	0	0
130084206	Tank vehicle KWW 34, clutch pipe delivery	27.02.2013	09:16	9,2	colorless, clear	0,80	0	0	0	0	0	0
130084207	Tank vehicle KWW 35, clutch pipe delivery	27.02.2013	09:18	8,3	colorless, clear	0,69	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775  
Report February 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130084208	Tank vehicle KWW 36, clutch pipe delivery	27.02.2013	09:25	8,0	colorless, clear	0,71	0	0	0	0	0	0
130084209	Tank vehicle KWW 37, clutch pipe delivery	27.02.2013	09:54	7,2	colorless, clear	0,60	0	0	0	0	0	0
130084211	Tank vehicle KWW 39, clutch pipe delivery	27.02.2013	09:34	8,0	colorless, clear	0,73	0	0	0	0	0	0
130084212	Tank vehicle KWW 40, clutch pipe delivery	27.02.2013	09:30	8,3	colorless, clear	0,82	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, March 04, 2013