

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775**  
**Report January 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
120987408	Drinking water Delivery Tap 1	30.01.2013	10:30	12,0	colorless, clear	0,92	0	0	0	0	0	0
120987409	Drinking water Delivery Tap 2	30.01.2013	10:20	11,5	colorless, clear	0,92	0	0	0	0	0	0
120987410	Drinking water Delivery Tap 3	30.01.2013	10:16	11,6	colorless, clear	0,37	0	0	0	0	0	0
120987411	Drinking water Delivery Tap 4	30.01.2013	10:12	12,6	colorless, clear	0,99	0	0	0	0	0	0
120987412	Tank vehicle KWW 28, clutch pipe delivery	30.01.2013	09:28	11,8	colorless, clear	0,70	0	0	0	0	0	0
120987420	Tank vehicle KWW 29, clutch pipe delivery	30.01.2013	10:05	12,1	colorless, clear	0,78	0	0	0	0	0	0
120987421	Tank vehicle KWW 30, clutch pipe delivery	30.01.2013	09:44	12,3	colorless, clear	0,67	0	0	0	0	0	0
120987423	Tank vehicle KWW 32, clutch pipe delivery	30.01.2013	09:47	12,1	colorless, clear	0,70	0	0	0	0	0	0
120987424	Tank vehicle KWW 33, clutch pipe delivery	30.01.2013	10:02	12,6	colorless, clear	0,74	0	0	0	0	0	0
120987425	Tank vehicle KWW 34, clutch pipe delivery	30.01.2013	10:07	12,1	colorless, clear	0,70	0	0	0	0	0	0
120987426	Tank vehicle KWW 35, clutch pipe delivery	30.01.2013	09:50	12,7	colorless, clear	0,48	0	0	0	0	0	0
120987428	Tank vehicle KWW 37, clutch pipe delivery	30.01.2013	09:36	11,5	colorless, clear	0,76	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775  
Report January 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
120987429	Tank vehicle KWW 38, clutch pipe delivery	30.01.2013	10:22	11,6	colorless, clear	0,64	0	0	0	0	0	0
120987430	Tank vehicle KWW 39, clutch pipe delivery	30.01.2013	09:34	11,6	colorless, clear	0,77	0	0	0	0	0	0
120987431	Tank vehicle KWW 40, clutch pipe delivery	30.01.2013	09:57	11,5	colorless, clear	0,65	0	0	0	0	0	0
120987432	Tank vehicle KWW 41, clutch pipe delivery	30.01.2013	09:59	12,1	colorless, clear	0,60	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, February 07, 2013

\_\_\_\_\_