

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 25.06.2013

Dienstag, 2. Juli 2013

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-28 clutch pipe delivery	15,1	7,7	0,21	0	16	0	0	0	0
Tank vehicle KWW-29 clutch pipe delivery	15,2	7,6	0,35	0	7	0	0	0	0
Tank vehicle KWW-30 clutch pipe delivery	17,4	7,8	0,64	0	0	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	18,1	8,0	0,61	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	18,0	8,0	0,66	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	17,7	8,1	0,64	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	18,0	7,8	0,64	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	18,4	7,8	0,69	0	1	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	18,5	7,8	0,45	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	17,8	8,0	0,75	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	18,2	7,8	0,53	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	18,1	7,9	0,62	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	18,2	7,7	0,58	0	1	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	18,1	7,6	0,65	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	18,2	7,6	0,68	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	18,9	7,6	1,12	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	18,4	7,5	1,12	0	0	0	0	0	0