

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 07.03.2013

Freitag, 15. März 2013

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-29 clutch pipe delivery	10,5	7,6	0,78	0	0	0	0	0	0
Tank vehicle KWW-30 clutch pipe delivery	11,9	7,7	0,62	0	0	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	11,2	7,6	0,74	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	12,5	7,9	0,66	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	11,5	7,8	0,62	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	11,6	7,8	0,71	1	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	12,2	7,9	0,68	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	10,9	7,7	0,41	0	2	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	11,2	7,7	0,68	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	11,6	7,9	0,73	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	11,9	7,6	0,71	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,2	7,7	0,71	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	10,6	7,6	0,60	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	11,1	7,6	1,05	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	10,9	7,5	0,93	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	11,3	7,4	1,56	0	0	0	0	0	0