

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775  
Report May 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130354788	Drinking water Delivery Tap 2	29.05.2013	10:05	16,4	colorless, clear	0,74	0	0	0	0	0	0
130354789	Drinking water Delivery Tap 3	29.05.2013	10:03	16,6	colorless, clear	0,42	0	0	0	0	0	0
130354790	Drinking water Delivery Tap 4	29.05.2013	09:59	16,4	colorless, clear	0,28	0	0	0	0	0	0
130354791	Tank vehicle KWW 28, clutch pipe delivery	29.05.2013	09:27	15,2	colorless, clear	0,58	0	0	0	0	0	0
130354792	Tank vehicle KWW 29, clutch pipe delivery	29.05.2013	09:41	16,4	colorless, clear	0,68	0	0	0	0	0	0
130354794	Tank vehicle KWW 31, clutch pipe delivery	29.05.2013	10:09	15,9	colorless, clear	0,48	0	0	0	0	0	0
130354795	Tank vehicle KWW 32, clutch pipe delivery	29.05.2013	09:18	17,6	colorless, clear	0,64	0	0	0	0	0	0
130354796	Tank vehicle KWW 33, clutch pipe delivery	29.05.2013	09:25	17,4	colorless, clear	0,73	0	0	0	0	0	0
130354797	Tank vehicle KWW 34, clutch pipe delivery	29.05.2013	09:44	16,6	colorless, clear	0,61	0	0	0	0	0	0
130354798	Tank vehicle KWW 35, clutch pipe delivery	29.05.2013	09:30	17,4	colorless, clear	0,67	0	0	0	0	0	0
130354800	Tank vehicle KWW 37, clutch pipe delivery	29.05.2013	09:22	16,9	colorless, clear	0,63	0	0	0	0	0	0
130354801	Tank vehicle KWW 38, clutch pipe delivery	29.05.2013	09:53	15,7	colorless, clear	0,84	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500402775  
Report May 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130354802	Tank vehicle KWW 39, clutch pipe delivery	29.05.2013	09:49	16,7	colorless, clear	0,72	0	0	0	0	0	0
130354803	Tank vehicle KWW 40, clutch pipe delivery	29.05.2013	09:37	15,9	colorless, clear	0,73	0	0	0	0	0	0
130354804	Tank vehicle KWW 41, clutch pipe delivery	29.05.2013	09:33	16,4	colorless, clear	0,70	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, June 05, 2013