

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500403775
Report November 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130991089	Drinking water Delivery Tap 1	27.11.2013	09:50	15,3	colorless, clear	1,27	0	0	0	0	0	0
130991090	Drinking water Delivery Tap 2	27.11.2013	09:55	13,4	colorless, clear	1,96	0	0	0	0	0	0
130991091	Drinking water Delivery Tap 3	27.11.2013	09:58	16,4	colorless, clear	1,84	0	0	0	0	0	0
130991092	Drinking water Delivery Tap 4	27.11.2013	10:00	14,9	colorless, clear	1,26	0	0	0	0	0	0
130991093	Tank vehicle KWW 28, clutch pipe delivery	27.11.2013	09:40	12,2	colorless, clear	1,74	0	0	0	0	0	0
130991095	Tank vehicle KWW 30, clutch pipe delivery	27.11.2013	10:15	8,8	colorless, clear	1,60	0	0	0	0	0	0
130991096	Tank vehicle KWW 31, clutch pipe delivery	27.11.2013	09:32	10,2	colorless, clear	1,53	0	0	0	0	0	0
130991099	Tank vehicle KWW 34, clutch pipe delivery	27.11.2013	10:45	9,2	colorless, clear	1,42	0	0	0	0	0	0
130991100	Tank vehicle KWW 35, clutch pipe delivery	27.11.2013	09:18	11,1	colorless, clear	1,48	0	0	0	0	0	0
130991101	Tank vehicle KWW 36, clutch pipe delivery	27.11.2013	10:13	12,2	colorless, clear	1,70	0	0	0	0	0	0
130991102	Tank vehicle KWW 37, clutch pipe delivery	27.11.2013	09:53	13,8	colorless, clear	1,98	0	0	0	0	0	0
130991103	Tank vehicle KWW 38, clutch pipe delivery	27.11.2013	09:43	11,4	colorless, clear	1,82	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500403775
Report November 2013**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
130991105	Tank vehicle KWW 40, clutch pipe delivery	27.11.2013	09:45	7,5	colorless, clear	1,45	0	0	0	0	0	0
130991106	Tank vehicle KWW 41, clutch pipe delivery	27.11.2013	09:20	11,1	colorless, clear	1,51	0	0	0	0	0	0
131108805	Tank vehicle KWW 42, clutch pipe delivery	27.11.2013	09:30	13,9	colorless, clear	1,80	0	0	0	0	0	0
131108806	Tank vehicle KWW 43, clutch pipe delivery	27.11.2013	09:35	14,3	colorless, clear	1,71	0	0	0	0	0	0

Assessment:

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, December 06, 2013