

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 26.09.2013

Montag, 7. Oktober 2013

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-28 clutch pipe delivery	17,7		3,50	0	0	0	0	0	0
Tank vehicle KWW-29 clutch pipe delivery	18,0	8,0	1,24	0	0	0	0	0	0
Tank vehicle KWW-30 clutch pipe delivery	18,7	8,0	0,78	0	2	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	18,3	7,9	0,81	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	18,2		1,72	0	1	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	18,4	8,2	0,73	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	17,9	8,1	0,81	0	1	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	18,2	7,9	0,79	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	18,3	8,1	0,74	0	1	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	18,0	7,8	0,80	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	18,1	8,0	0,75	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	18,3	7,8	0,70	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	18,2	7,8	0,95	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	18,0		0,77	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	18,6	7,7	0,93	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	18,5	7,6	1,00	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	18,4	7,6	0,51	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	17,9	7,7	0,53	0	0	0	0	0	0