

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report April 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
140371920	Drinking water Delivery Tap 1	29.04.2014	10:20	17,6	colorless, clear	0,74	0	0	0	0	0	0
140371921	Drinking water Delivery Tap 2	29.04.2014	10:10	17,4	colorless, clear	0,77	0	0	0	0	0	0
140371922	Drinking water Delivery Tap 3	29.04.2014	10:06	17,8	colorless, clear	0,45	0	0	0	0	0	0
140371924	Drinking water Delivery Tap 4	29.04.2014	10:04	17,8	colorless, clear	0,26	0	0	0	0	0	0
140371925	Tank vehicle KWW 30, clutch pipe delivery	29.04.2014	09:25	16,0	colorless, clear	0,51	0	0	0	0	0	0
140371926	Tank vehicle KWW 31, clutch pipe delivery	29.04.2014	09:30	16,5	colorless, clear	0,72	0	0	0	0	0	0
140371927	Tank vehicle KWW 32, clutch pipe delivery	29.04.2014	09:32	16,9	colorless, clear	0,70	0	0	0	0	0	0
140371929	Tank vehicle KWW 34, clutch pipe delivery	29.04.2014	09:50	17,4	colorless, clear	0,72	0	0	0	0	0	0
140371930	Tank vehicle KWW 35, clutch pipe delivery	29.04.2014	09:53	17,2	colorless, clear	0,86	0	0	0	0	0	0
140371931	Tank vehicle KWW 36, clutch pipe delivery	29.04.2014	09:48	16,5	colorless, clear	0,65	0	0	0	0	0	0
140371933	Tank vehicle KWW 38, clutch pipe delivery	29.04.2014	09:28	17,0	colorless, clear	0,73	0	0	0	0	0	0
140371935	Tank vehicle KWW 40, clutch pipe delivery	29.04.2014	10:00	17,4	colorless, clear	0,72	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report April 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
140371936	Tank vehicle KWW 41, clutch pipe delivery	29.04.2014	10:13	16,4	colorless, clear	0,57	0	0	0	0	0	0
140371937	Tank vehicle KWW 42, clutch pipe delivery	29.04.2014	09:35	17,0	colorless, clear	0,72	0	0	0	0	0	0
140371938	Tank vehicle KWW 43, clutch pipe delivery	29.04.2014	09:23	17,4	colorless, clear	0,72	0	0	0	0	0	0

Assessment:

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, May 05, 2014
