

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 10.12.2014

Mittwoch, 7. Januar 2015

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-30 clutch pipe delivery	12,6	7,8	0,84	1	1	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	12,8	7,9	0,67	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	8,7	8,1	0,58	2	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	12,7	7,9	0,69	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	9,8	8,1	0,81	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	9,8	8,0	0,61	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	6,0	8,0	0,64	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	9,8	8,0	0,69	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	10,7	8,2	0,70	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	9,2	8,4	0,71	0	1	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	9,0	7,9	0,79	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	10,4	8,0	0,63	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	10,3	8,1	0,85	2	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	11,5	8,2	0,80	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	12,1	7,8	0,69	0	2	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	12,4	7,8	0,82	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	13,2	7,6	0,40	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	13,2	7,6	0,82	1	0	0	0	0	0