

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report January 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
131240155	Drinking water Delivery Tap 1	29.01.2014	09:58	11,9	colorless, clear	0,69	0	0	0	0	0	0
131240156	Drinking water Delivery Tap 2	29.01.2014	10:00	12,4	colorless, clear	0,71	0	0	0	0	0	0
131240157	Drinking water Delivery Tap 3	29.01.2014	10:07	12,4	colorless, clear	0,71	0	0	0	0	0	0
131240158	Drinking water Delivery Tap 4	29.01.2014	10:13	12,5	colorless, clear	0,91	0	0	0	0	0	0
131240164	Tank vehicle KWW 30, clutch pipe delivery	29.01.2014	09:30	10,6	colorless, clear	0,66	0	0	0	0	0	0
131240185	Tank vehicle KWW 31, clutch pipe delivery	29.01.2014	09:35	11,1	colorless, clear	0,62	0	0	0	0	0	0
131240186	Tank vehicle KWW 32, clutch pipe delivery	29.01.2014	09:40	7,8	colorless, clear	0,64	0	0	0	0	0	0
131240187	Tank vehicle KWW 33, clutch pipe delivery	29.01.2014	09:43	10,8	colorless, clear	0,63	0	0	0	0	0	0
131240189	Tank vehicle KWW 35, clutch pipe delivery	29.01.2014	10:05	10,6	colorless, clear	0,67	0	0	0	0	0	0
131240190	Tank vehicle KWW 36, clutch pipe delivery	29.01.2014	09:27	9,5	colorless, clear	0,60	0	0	0	0	0	0
131240191	Tank vehicle KWW 37, clutch pipe delivery	29.01.2014	09:45	9,5	colorless, clear	0,64	0	0	0	0	0	0
131240192	Tank vehicle KWW 38, clutch pipe delivery	29.01.2014	09:37	10,2	colorless, clear	0,63	0	0	0	0	-	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report January 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
131240193	Tank vehicle KWW 39, clutch pipe delivery	29.01.2014	09:48	8,6	colorless, clear	0,51	0	0	0	0	0	0
131240194	Tank vehicle KWW 40, clutch pipe delivery	29.01.2014	09:53	11,4	colorless, clear	0,65	0	0	0	0	0	0
131240198	Tank vehicle KWW 41, clutch pipe delivery	29.01.2014	09:24	9,9	colorless, clear	0,61	0	0	0	0	0	0
131240199	Tank vehicle KWW 41, clutch pipe delivery	29.01.2014	09:50	12,4	colorless, clear	0,63	0	0	0	0	0	0
131240200	Tank vehicle KWW 43, clutch pipe delivery	29.01.2014	09:32	9,2	colorless, clear	0,65	0	0	0	0	0	0

Assessment:

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, January 05, 2014 _____