

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 24.06.2014

Mittwoch, 2. Juli 2014

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-31 clutch pipe delivery	20,8	7,8	0,52	0	1	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	19,5	7,8	0,62	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	19,6	7,6	0,50	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	19,6	7,6	0,60	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	19,3	7,7	0,60	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	20,6	7,9	0,53	1	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	21,1	8,1	0,52	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	20,2	7,9	0,57	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	21,1	7,9	0,51	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	20,4	7,8	0,67	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	19,1	7,8	0,67	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	19,4	7,2	0,67	2	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	18,9	7,5	0,65	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	19,0	7,5	0,40	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	18,7	7,5	0,30	0	0	0	0	0	0