

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report May 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
140486645	Drinking water Delivery Tap 1	27.05.2014	08:59	19,1	colorless, clear	0,83	0	0	0	0	0	0
140486970	Drinking water Delivery Tap 2	27.05.2014	09:01	18,3	colorless, clear	0,74	0	0	0	0	0	0
140486971	Drinking water Delivery Tap 3	27.05.2014	09:06	18,8	colorless, clear	0,41	0	0	0	0	0	0
140486972	Drinking water Delivery Tap 4	27.05.2014	09:10	18,7	colorless, clear	0,35	0	0	0	0	0	0
140486973	Tank vehicle KWW 30, clutch pipe delivery	27.05.2014	09:22	19,1	colorless, clear	0,50	0	0	0	0	0	0
140486974	Tank vehicle KWW 31, clutch pipe delivery	27.05.2014	10:20	18,7	colorless, clear	0,51	0	0	0	0	0	0
140486975	Tank vehicle KWW 32, clutch pipe delivery	27.05.2014	09:47	19,4	colorless, clear	0,55	0	0	0	0	0	0
140486976	Tank vehicle KWW 33, clutch pipe delivery	27.05.2014	09:55	18,7	colorless, clear	0,64	0	0	0	0	0	0
140486977	Tank vehicle KWW 34, clutch pipe delivery	27.05.2014	09:48	19,0	colorless, clear	0,67	0	0	0	0	0	0
140486978	Tank vehicle KWW 35, clutch pipe delivery	27.05.2014	09:52	19,4	colorless, clear	0,66	0	0	0	0	0	0
140486980	Tank vehicle KWW 37, clutch pipe delivery	27.05.2014	09:32	19,1	colorless, clear	0,53	0	0	0	0	0	0
140486981	Tank vehicle KWW 38, clutch pipe delivery	27.05.2014	09:30	18,2	colorless, clear	0,53	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report May 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
140486982	Tank vehicle KWW 39, clutch pipe delivery	27.05.2014	09:15	19,2	colorless, clear	0,50	0	0	0	0	0	0
140486983	Tank vehicle KWW 40, clutch pipe delivery	27.05.2014	09:24	18,1	colorless, clear	0,52	0	0	0	0	0	0
140487715	Tank vehicle KWW 42, clutch pipe delivery	27.05.2014	09:38	19,2	colorless, clear	0,64	6	8	0	0	0	0
140487716	Tank vehicle KWW 43, clutch pipe delivery	27.05.2014	09:35	19,4	colorless, clear	0,54	0	0	0	0	0	0

Assessment:

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, June 04, 2014