

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report September 2014 (Control)**

| Sample ID | Sample designation | Sampling day | Sampling time | Water temperature °C | Description | Free chlorine mg/l | DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100 | DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100 | Escherichia coli KBE/100 ml Limit Value 0 | Coliforms KBE/100 ml Limit Value 0 | Pseudomonas aeruginosa KBE/100 ml Limit Value 0 | Enterococci KBE/100 ml Limit Value 0 |
|-----------|-------------------------------|--------------|---------------|----------------------|------------------|--------------------|--|--|---|------------------------------------|---|--------------------------------------|
| 140964727 | Drinking water Delivery Tap 1 | 02.09.2014 | 10:20 | 16,4 | colorless, clear | 0,38 | 1 | 0 | 0 | 0 | 0 | 0 |

Assessment:

The microbiological quality of the tested sample is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, September 05, 2014 _____