

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report July 2014 (Control)**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
140791509	Tank vehicle KWW 33, clutch pipe delivery	16.07.2014	09:00	18,8	colorless, clear	0,60	0	0	0	0	0	0

Assessment:

The microbiological quality of the tested sample is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, July 22, 2014 _____