

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report November 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
141262943	Drinking water Delivery Tap 1	26.11.2014	10:05	15,1	colorless, clear	1,01	0	0	0	0	0	0
141262944	Drinking water Delivery Tap 2	26.11.2014	10:10	15,7	colorless, clear	0,76	0	0	0	0	0	0
141262945	Drinking water Delivery Tap 3	26.11.2014	10:15	14,9	colorless, clear	0,40	0	0	0	0	0	0
141262946	Drinking water Delivery Tap 4	26.11.2014	10:20	15,1	colorless, clear	1,06	0	0	0	0	0	0
141262949	Tank vehicle KWW 31, clutch pipe delivery	26.11.2014	09:00	15,9	colorless, clear	0,50	0	0	0	0	0	0
141263151	Tank vehicle KWW 32, clutch pipe delivery	26.11.2014	09:05	10,3	colorless, clear	0,78	0	0	0	0	0	0
141263152	Tank vehicle KWW 33, clutch pipe delivery	26.11.2014	10:00	14,0	colorless, clear	0,88	0	0	0	0	0	0
141263153	Tank vehicle KWW 34, clutch pipe delivery	26.11.2014	09:50	14,8	colorless, clear	0,91	0	0	0	0	0	0
141263154	Tank vehicle KWW 35, clutch pipe delivery	26.11.2014	09:30	12,7	colorless, clear	0,72	0	0	0	0	0	0
141263155	Tank vehicle KWW 36, clutch pipe delivery	26.11.2014	09:25	11,9	colorless, clear	0,86	0	0	0	0	0	0
141263156	Tank vehicle KWW 37, clutch pipe delivery	26.11.2014	09:45	11,6	colorless, clear	0,92	0	0	0	0	0	0
141263157	Tank vehicle KWW 38, clutch pipe delivery	26.11.2014	09:10	12,6	colorless, clear	0,39	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report November 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
141263158	Tank vehicle KWW 39, clutch pipe delivery	26.11.2014	09:20	11,5	colorless, clear	0,64	0	0	0	0	0	0
141263159	Tank vehicle KWW 40, clutch pipe delivery	26.11.2014	09:40	12,1	colorless, clear	0,77	0	0	0	0	0	0
141263160	Tank vehicle KWW 41, clutch pipe delivery	26.11.2014	09:55	11,0	colorless, clear	0,71	0	0	0	0	0	0
141263161	Tank vehicle KWW 42, clutch pipe delivery	26.11.2014	09:50	13,0	colorless, clear	0,89	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, December 05, 2014 _____