

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981**  
**Report October 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
141042311	Drinking water Delivery Tap 1	29.10.2014	09:40	18,7	colorless, clear	0,84	0	0	0	0	0	0
141042312	Drinking water Delivery Tap 2	29.10.2014	09:45	17,9	colorless, clear	0,81	0	0	0	0	0	0
141042313	Drinking water Delivery Tap 3	29.10.2014	09:50	17,9	colorless, clear	0,30	0	0	0	0	0	0
141042314	Drinking water Delivery Tap 4	29.10.2014	09:55	18,0	colorless, clear	0,79	0	0	0	0	0	0
141042315	Tank vehicle KWW 30, clutch pipe delivery	29.10.2014	09:35	18,1	colorless, clear	0,81	0	0	0	0	0	0
141042316	Tank vehicle KWW 31, clutch pipe delivery	29.10.2014	09:40	18,0	colorless, clear	0,67	0	0	0	0	0	0
141042317	Tank vehicle KWW 32, clutch pipe delivery	29.10.2014	09:30	16,4	colorless, clear	0,82	0	0	0	0	0	0
141042318	Tank vehicle KWW 33, clutch pipe delivery	29.10.2014	08:55	14,9	colorless, clear	0,81	0	0	0	0	0	0
141042319	Tank vehicle KWW 34, clutch pipe delivery	29.10.2014	09:10	16,4	colorless, clear	0,75	0	0	0	0	0	0
141042320	Tank vehicle KWW 35, clutch pipe delivery	29.10.2014	09:25	15,4	colorless, clear	0,73	0	0	0	0	0	0
141042321	Tank vehicle KWW 36, clutch pipe delivery	29.10.2014	08:45	17,7	colorless, clear	0,60	0	0	0	0	0	0
141042323	Tank vehicle KWW 38, clutch pipe delivery	29.10.2014	09:15	15,2	colorless, clear	0,54	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report October 2014**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
141042324	Tank vehicle KWW 39, clutch pipe delivery	29.10.2014	09:05	15,4	colorless, clear	0,64	0	0	0	0	0	0
141042325	Tank vehicle KWW 40, clutch pipe delivery	29.10.2014	09:10	15,4	colorless, clear	0,85	0	0	0	0	0	0
141042327	Tank vehicle KWW 42, clutch pipe delivery	29.10.2014	09:20	15,8	colorless, clear	0,68	0	0	0	0	0	0
141042328	Tank vehicle KWW 43, clutch pipe delivery	29.10.2014	09:00	15,5	colorless, clear	0,80	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, November 06, 2014 \_\_\_\_\_