

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

## Fraport drinking water tank vehicles and delivery

Sampling date 29.09.2014

Donnerstag, 9. Oktober 2014

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-30 clutch pipe delivery	17,7	7,6	0,81	0	0	0	0	0	0
Tank vehicle KWW-31 clutch pipe delivery	17,9	7,7	0,79	0	3	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	18,1	7,6	0,88	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	18,4	7,7	0,79	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	17,5	7,6	0,96	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	18,3	7,7	0,79	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	18,0	7,8	0,80	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	17,6	7,6	0,88	1	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	17,9	8,1	0,86	0	1	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	17,7	7,6	0,80	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	17,9	7,8	0,75	0	1	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	17,6	7,6	0,76	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	18,1	7,6	0,80	2	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	18,3	7,8	0,71	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	17,2	7,5	1,03	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	17,8	7,5	0,97	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	17,6	7,5	1,35	1	1	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	17,2	7,6	0,46	2	0	0	0	0	0