

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report April 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150278128	Drinking water Delivery Tap 1	29.04.2015	11:04	15,0	colorless, clear	0,70	0	0	0	0	0	0
150278129	Drinking water Delivery Tap 2	29.04.2015	11:24	16,2	colorless, clear	0,66	0	0	0	0	0	0
150278130	Drinking water Delivery Tap 3	29.04.2015	11:26	15,6	colorless, clear	0,52	0	0	0	0	0	0
150278131	Drinking water Delivery Tap 4	29.04.2015	11:30	16,0	colorless, clear	0,62	0	0	0	0	0	0
150278133	Tank vehicle KWW 31, clutch pipe delivery	29.04.2015	10:45	12,6	colorless, clear	0,66	0	0	0	0	0	0
150278134	Tank vehicle KWW 32, clutch pipe delivery	29.04.2015	10:52	15,9	colorless, clear	0,62	0	0	0	0	0	0
150278135	Tank vehicle KWW 33, clutch pipe delivery	29.04.2015	11:18	15,6	colorless, clear	0,62	0	0	0	0	0	0
150278136	Tank vehicle KWW 34, clutch pipe delivery	29.04.2015	11:14	14,8	colorless, clear	0,40	0	0	0	0	0	0
150278137	Tank vehicle KWW 35, clutch pipe delivery	29.04.2015	10:54	15,8	colorless, clear	0,62	0	0	0	0	0	0
150278138	Tank vehicle KWW 36, clutch pipe delivery	29.04.2015	10:58	14,4	colorless, clear	0,50	0	0	0	0	0	0
150278139	Tank vehicle KWW 37, clutch pipe delivery	29.04.2015	11:10	15,3	colorless, clear	0,38	2	4	0	0	0	0
150278140	Tank vehicle KWW 38, clutch pipe delivery	29.04.2015	11:06	154,0	colorless, clear	0,48	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report April 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150278141	Tank vehicle KWW 39, clutch pipe delivery	29.04.2015	11:16	15,8	colorless, clear	0,60	0	0	0	0	0	0
150278142	Tank vehicle KWW 40, clutch pipe delivery	29.04.2015	10:45	15,0	colorless, clear	0,46	0	0	0	0	0	0
150278143	Tank vehicle KWW 41, clutch pipe delivery	29.04.2015	10:56	15,2	colorless, clear	0,36	1	0	0	0	0	0
150278144	Tank vehicle KWW 42, clutch pipe delivery	29.04.2015	10:40	14,8	colorless, clear	0,58	0	0	0	0	0	0
150278146	Tank vehicle KWW 43, clutch pipe delivery	29.04.2015	11:00	15,8	colorless, clear	0,48	0	0	0	0	0	0
150278147	Tank vehicle KWW 44, clutch pipe delivery	29.04.2015	10:50	14,4	colorless, clear	0,54	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, May 07, 2015