

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report August 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150685672	Drinking water Delivery Tap 1	26.08.2015	09:25	21,0	colorless, clear	0,94	0	0	0	0	0	0
150685673	Drinking water Delivery Tap 2	26.08.2015	09:27	20,5	colorless, clear	0,60	0	0	0	0	0	0
150685674	Drinking water Delivery Tap 3	26.08.2015	09:30	20,0	colorless, clear	0,90	0	0	0	0	0	0
150685675	Drinking water Delivery Tap 4	26.08.2015	09:35	19,8	colorless, clear	0,64	0	0	0	0	0	0
<b>150685677</b>	<b>Tank vehicle KWW 31, clutch pipe delivery</b>	26.08.2015	<b>08:35</b>	<b>20,0</b>	<b>colorless, clear</b>	<b>0,03</b>	<b>64</b>	<b>170</b>	<b>0</b>	<b>0</b>	<b>&gt;100</b>	<b>0</b>
150685678	Tank vehicle KWW 32, clutch pipe delivery	26.08.2015	08:32	19,8	colorless, clear	0,52	0	0	0	0	0	0
150685679	Tank vehicle KWW 33, clutch pipe delivery	26.08.2015	08:52	21,6	colorless, clear	0,94	0	0	0	0	0	0
150685680	Tank vehicle KWW 34, clutch pipe delivery	26.08.2015	08:50	21,5	colorless, clear	0,90	0	2	0	0	0	0
150685681	Tank vehicle KWW 35, clutch pipe delivery	26.08.2015	09:00	20,4	colorless, clear	0,74	0	0	0	0	0	0
150685682	Tank vehicle KWW 36, clutch pipe delivery	26.08.2015	08:45	20,6	colorless, clear	0,58	0	1	0	0	0	0
150685683	Tank vehicle KWW 37, clutch pipe delivery	26.08.2015	09:05	20,8	colorless, clear	0,56	0	0	0	0	0	0
150685684	Tank vehicle KWW 38, clutch pipe delivery	26.08.2015	08:42	20,8	colorless, clear	0,64	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report August 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150685685	Tank vehicle KWW 39, clutch pipe delivery	26.08.2015	08:55	21,0	colorless, clear	0,78	0	0	0	0	0	0
150685686	Tank vehicle KWW 40, clutch pipe delivery	26.08.2015	09:20	20,8	colorless, clear	0,86	0	0	0	0	0	0
150685688	Tank vehicle KWW 42, clutch pipe delivery	26.08.2015	08:30	21,0	colorless, clear	0,68	0	0	0	0	0	0
150685689	Tank vehicle KWW 43, clutch pipe delivery	26.08.2015	09:15	21,2	colorless, clear	0,58	0	0	0	0	0	0
150685690	Tank vehicle KWW 44, clutch pipe delivery	26.08.2015	09:10	20,4	colorless, clear	0,74	0	0	0	0	0	0

**Assessment:**

According to the investigations of the German Drinking Water Regulation the following parameter of the testing sample 150685677 are out of limit value: **DEV agar after 44 ± 4 h at 36 ± 2°C, Pseudomonas aeruginosa**  
The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, September 01, 2015