

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 15.12.2015

Montag, 4. Januar 2016

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony	colony	Escherichia	Coliforms	Pseudomonas	Enterococcus
				count at 22°C [KBE/ml] limit value 100	count at 36°C [KBE/ml] limit value 100	coli [KBE/100ml] limit value 0	[KBE/100ml] limit value 0	aeruginosa [KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-31 clutch pipe delivery	11,5	7,9	0,89	1	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	8,6	7,7	0,69	0	1	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	10,4	7,7	0,88	0	1	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	12,0	7,7	0,84	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	12,3	8,5	0,91	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	11,8	7,7	0,97	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	12,4	7,6	0,89	0	2	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	12,2	7,8	0,76	1	1	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	13,3	7,5	0,97	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,3	7,8	0,87	1	1	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	11,9	7,5	0,91	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	12,7	7,6	0,87	4	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	13,5	7,6	0,67	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	14,4	7,5	1,04	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	13,4	7,6	0,86	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	13,5	7,5	0,65	0	0	0	0	0	0