

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981**  
**Report February 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150084119	Drinking water Delivery Tap 1	04.02.2015	09:45	10,2	colorless, clear	0,64	0	0	0	0	0	0
150084120	Drinking water Delivery Tap 2	04.02.2015	09:50	10,8	colorless, clear	0,64	0	0	0	0	0	0
150084121	Drinking water Delivery Tap 3	04.02.2015	10:10	10,8	colorless, clear	0,50	0	0	0	0	0	0
150084122	Drinking water Delivery Tap 4	04.02.2015	10:00	11,0	colorless, clear	0,80	0	0	0	0	0	0
150084124	Tank vehicle KWW 31, clutch pipe delivery	04.02.2015	10:10	7,8	colorless, clear	0,53	0	0	0	0	0	0
150084125	Tank vehicle KWW 32, clutch pipe delivery	04.02.2015	09:15	10,8	colorless, clear	0,56	0	0	0	0	0	0
150084221	Tank vehicle KWW 33, clutch pipe delivery	04.02.2015	09:40	10,0	colorless, clear	0,56	0	0	0	0	0	0
150084222	Tank vehicle KWW 34, clutch pipe delivery	04.02.2015	09:35	9,4	colorless, clear	0,62	0	0	0	0	0	0
150084223	Tank vehicle KWW 35, clutch pipe delivery	04.02.2015	09:25	8,0	colorless, clear	0,55	0	0	0	0	0	0
150084224	Tank vehicle KWW 36, clutch pipe delivery	04.02.2015	09:45	8,8	colorless, clear	0,70	0	0	0	0	0	0
150084225	Tank vehicle KWW 37, clutch pipe delivery	04.02.2015	09:00	9,8	colorless, clear	0,52	0	0	0	0	0	0
150084226	Tank vehicle KWW 38, clutch pipe delivery	04.02.2015	09:20	11,2	colorless, clear	0,56	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report February 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150084227	Tank vehicle KWW 39, clutch pipe delivery	04.02.2015	09:30	8,0	colorless, clear	0,50	0	0	0	0	0	0
150084228	Tank vehicle KWW 40, clutch pipe delivery	04.02.2015	09:10	9,4	colorless, clear	0,50	0	0	0	0	0	0
150084229	Tank vehicle KWW 41, clutch pipe delivery	04.02.2015	09:15	9,0	colorless, clear	0,44	0	0	0	0	0	0
150084230	Tank vehicle KWW 42, clutch pipe delivery	04.02.2015	09:30	8,6	colorless, clear	0,54	0	0	0	0	0	0
150084231	Tank vehicle KWW 43, clutch pipe delivery	04.02.2015	09:20	10,4	colorless, clear	0,52	0	0	0	0	0	0
150112408	Tank vehicle KWW 44, clutch pipe delivery	04.02.2015	09:05	11,2	colorless, clear	0,50	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, February 11, 2015