

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report July 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150583119	Drinking water Delivery Tap 1	03.07.2015	09:25	21,0	colorless, clear	0,25	0	0	0	0	0	0
150583120	Drinking water Delivery Tap 2	03.07.2015	09:30	19,8	colorless, clear	0,97	0	1	0	0	0	0
150583121	Drinking water Delivery Tap 3	03.07.2015	09:35	19,7	colorless, clear	1,02	0	0	0	0	0	0
150583122	Drinking water Delivery Tap 4	03.07.2015	09:40	19,5	colorless, clear	0,81	0	0	0	0	0	0
150583124	Tank vehicle KWW 31, clutch pipe delivery	03.07.2015	08:20	29,1	colorless, clear	0,48	0	22	0	0	0	0
150583125	Tank vehicle KWW 32, clutch pipe delivery	03.07.2015	08:25	27,1	colorless, clear	0,53	0	1	0	0	0	0
150583126	Tank vehicle KWW 33, clutch pipe delivery	03.07.2015	10:00	27,5	colorless, clear	0,57	0	2	0	0	0	0
150583127	Tank vehicle KWW 34, clutch pipe delivery	03.07.2015	08:35	28,1	colorless, clear	0,50	0	1	0	0	0	0
150583128	Tank vehicle KWW 35, clutch pipe delivery	03.07.2015	09:05	23,9	colorless, clear	0,70	0	0	0	0	0	0
150583129	Tank vehicle KWW 36, clutch pipe delivery	03.07.2015	08:40	22,9	colorless, clear	0,63	0	2	0	0	0	0
150583130	Tank vehicle KWW 37, clutch pipe delivery	03.07.2015	08:15	25,2	colorless, clear	2,15	0	0	0	0	0	0
150583131	Tank vehicle KWW 38, clutch pipe delivery	03.07.2015	08:55	28,1	colorless, clear	0,52	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981  
Report July 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150583132	Tank vehicle KWW 39, clutch pipe delivery	03.07.2015	08:30	25,1	colorless, clear	0,58	0	0	0	0	0	0
150583133	Tank vehicle KWW 40, clutch pipe delivery	03.07.2015	08:05	31,6	colorless, clear	<0,03	0	17	0	0	0	0
<b>150583134</b>	<b>Tank vehicle KWW 41, clutch pipe delivery</b>	<b>03.07.2015</b>	<b>09:15</b>	<b>30,1</b>	<b>colorless, clear</b>	<b>0,06</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>9</b>	<b>0</b>
150583135	Tank vehicle KWW 42, clutch pipe delivery	03.07.2015	09:00	24,6	colorless, clear	0,69	0	0	0	0	0	0
150583136	Tank vehicle KWW 43, clutch pipe delivery	03.07.2015	09:20	22,0	colorless, clear	1,00	0	0	0	0	0	0
150583137	Tank vehicle KWW 44, clutch pipe delivery	03.07.2015	08:45	26,5	colorless, clear	0,43	0	0	0	0	0	0

**Assessment:**

According to the investigations of the German Drinking Water Regulation the following parameter of the testing sample 150583134 is out of limit value: **Pseudomonas aeruginosa**

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, July 10, 2015