

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 23.06.2015

Mittwoch, 1. Juli 2015

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-31 clutch pipe delivery	17,0	7,8	0,60	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	14,9	7,7	0,08	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	15,0	8,1	0,66	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	15,5	7,8	0,76	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	14,5	7,9	0,87	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	15,4	8,2	0,80	0	0	0	1	0	0
Tank vehicle KWW-38 clutch pipe delivery	16,8	8,1	0,71	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	15,8	7,8	0,71	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	16,9	8,0	0,59	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	17,1	7,7	0,76	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	15,3	8,2	0,81	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	14,5	8,4	0,66	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	15,1	7,7	0,42	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	17,0	7,6	0,75	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	17,4	7,6	1,20	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	17,2	7,7	0,91	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	17,5	7,7	1,16	0	0	0	0	0	0