

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

## Fraport drinking water tank vehicles and delivery

Sampling date 24.03.2015

Mittwoch, 8. April 2015

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-31 clutch pipe delivery	12,2	7,5	0,90	0	0	0	0	0	0
Tank vehicle KWW-32 clutch pipe delivery	12,4	7,6	0,79	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	13,2	7,5	0,62	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	11,6	7,8	0,63	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	12,6	7,5	1,15	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	11,1	7,9	0,68	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	11,1	7,6	0,75	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	12,3	7,7	0,80	0	12	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,5	7,6	0,94	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	12,4	7,4	1,09	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	10,3	7,8	0,70	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	11,5	7,5	1,06	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	12,1	7,5	1,09	0	14	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,9	7,6	0,87	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	11,6	7,4	0,98	0	0	0	0	0	0