

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report May 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150391730	Drinking water Delivery Tap 1	20.05.2015	09:40	20,0	colorless, clear	0,68	0	0	0	0	0	0
150391731	Drinking water Delivery Tap 2	20.05.2015	09:45	17,0	colorless, clear	0,78	0	2	0	0	0	0
150391732	Drinking water Delivery Tap 3	20.05.2015	09:50	17,0	colorless, clear	0,50	0	0	0	0	0	0
150391733	Drinking water Delivery Tap 4	20.05.2015	10:15	17,4	colorless, clear	0,84	0	0	0	0	0	0
150391735	Tank vehicle KWW 31, clutch pipe delivery	20.05.2015	10:10	15,6	colorless, clear	0,34	0	0	0	0	0	0
150391739	Tank vehicle KWW 32, clutch pipe delivery	20.05.2015	09:00	16,4	colorless, clear	1,10	0	0	0	0	0	0
150391740	Tank vehicle KWW 33, clutch pipe delivery	20.05.2015	09:20	18,0	colorless, clear	0,40	0	0	0	0	0	0
150391741	Tank vehicle KWW 34, clutch pipe delivery	20.05.2015	09:15	14,8	colorless, clear	0,46	0	0	0	0	0	0
150391742	Tank vehicle KWW 35, clutch pipe delivery	20.05.2015	10:05	16,6	colorless, clear	0,70	0	0	0	0	0	0
150391743	Tank vehicle KWW 36, clutch pipe delivery	20.05.2015	10:00	17,0	colorless, clear	0,96	0	0	0	0	0	0
150391744	Tank vehicle KWW 37, clutch pipe delivery	20.05.2015	09:35	17,0	colorless, clear	0,54	0	0	0	0	0	0
150391746	Tank vehicle KWW 38, clutch pipe delivery	20.05.2015	09:25	14,2	colorless, clear	0,24	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report May 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150391747	Tank vehicle KWW 39, clutch pipe delivery	20.05.2015	09:15	18,0	colorless, clear	0,94	0	0	0	0	0	0
150391748	Tank vehicle KWW 40, clutch pipe delivery	20.05.2015	09:30	16,0	colorless, clear	0,60	0	0	0	0	0	0
150391749	Tank vehicle KWW 41, clutch pipe delivery	20.05.2015	10:00	16,4	colorless, clear	0,38	0	0	0	0	0	0
150391750	Tank vehicle KWW 42, clutch pipe delivery	20.05.2015	09:55	18,0	colorless, clear	0,56	0	0	0	0	0	0
150391751	Tank vehicle KWW 43, clutch pipe delivery	20.05.2015	09:10	16,4	colorless, clear	0,96	0	0	0	0	0	0
150391752	Tank vehicle KWW 44, clutch pipe delivery	20.05.2015	09:05	15,8	colorless, clear	0,90	0	1	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, May 26, 2015