

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report October 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150881208	Drinking water Delivery Tap 1	28.10.2015	09:00	16,5	colorless, clear	0,88	0	0	0	0	0	0
150881209	Drinking water Delivery Tap 2	28.10.2015	09:10	15,8	colorless, clear	0,68	0	0	0	0	0	0
150881210	Drinking water Delivery Tap 3	28.10.2015	09:16	15,6	colorless, clear	0,50	0	1	0	0	0	0
150881211	Drinking water Delivery Tap 4	28.10.2015	09:35	16,0	colorless, clear	1,00	0	0	0	0	0	0
150881212	Tank vehicle KWW 31, clutch pipe delivery	28.10.2015	08:35	16,4	colorless, clear	0,80	0	10	0	0	0	0
150881213	Tank vehicle KWW 32, clutch pipe delivery	28.10.2015	09:30	14,8	colorless, clear	0,64	0	0	0	0	0	0
150881214	Tank vehicle KWW 33, clutch pipe delivery	28.10.2015	08:45	12,8	colorless, clear	0,53	0	0	0	0	0	0
150881215	Tank vehicle KWW 34, clutch pipe delivery	28.10.2015	08:15	15,8	colorless, clear	0,62	0	0	0	0	0	0
150881216	Tank vehicle KWW 35, clutch pipe delivery	28.10.2015	08:40	14,0	colorless, clear	0,80	0	0	0	0	0	0
150881217	Tank vehicle KWW 36, clutch pipe delivery	28.10.2015	09:50	13,0	colorless, clear	0,60	0	0	0	0	0	0
150881218	Tank vehicle KWW 37, clutch pipe delivery	28.10.2015	08:25	14,6	colorless, clear	0,60	0	0	0	0	0	0
150881220	Tank vehicle KWW 38, clutch pipe delivery	28.10.2015	09:05	14,2	colorless, clear	0,66	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report October 2015**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
150881221	Tank vehicle KWW 39, clutch pipe delivery	28.10.2015	08:55	14,5	colorless, clear	0,60	0	0	0	0	0	0
150881222	Tank vehicle KWW 40, clutch pipe delivery	28.10.2015	08:15	16,4	colorless, clear	0,70	0	0	0	0	0	0
150881223	Tank vehicle KWW 41, clutch pipe delivery	28.10.2015	09:40	14,0	colorless, clear	0,60	0	0	0	0	0	0
150881224	Tank vehicle KWW 42, clutch pipe delivery	28.10.2015	08:25	14,5	colorless, clear	0,60	4	0	0	0	0	0
150881226	Tank vehicle KWW 44, clutch pipe delivery	28.10.2015	08:10	15,6	colorless, clear	0,78	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, November 03, 2015 _____