

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 23.09.2015

Montag, 5. Oktober 2015

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-32 clutch pipe delivery	16,6	7,9	0,64	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	14,5	8,2	0,67	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	16,7	8,0	0,66	0	2	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	14,7	8,0	0,77	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	17,2	8,0	0,69	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	17,7	7,9	0,65	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	17,7	7,9	0,65	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	17,7	8,2	0,69	0	1	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	17,2	7,9	0,67	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	17,1	7,9	0,69	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	18,1	8,0	0,88	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	17,6	8,0	0,71	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	17,1	8,2	0,80	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	18,7	7,9	0,71	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	18,2	7,7	0,74	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	18,2	7,7	0,52	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	19,1	7,8	0,30	0	0	0	0	0	0