

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-450049424
Report April 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160326751	Drinking water Delivery Tap 3	27.04.2016	09:15	14,0	colorless, clear	0,60	0	0	0	0	0	0
160326752	Drinking water Delivery Tap 4	27.04.2016	09:20	14,4	colorless, clear	1,10	0	1	0	0	0	0
160326753	Tank vehicle KWW 32, clutch pipe delivery	27.04.2016	09:55	14,2	colorless, clear	0,58	0	0	0	0	0	0
160326754	Tank vehicle KWW 33, clutch pipe delivery	27.04.2016	10:05	13,4	colorless, clear	0,56	0	0	0	0	0	0
160326755	Tank vehicle KWW 34, clutch pipe delivery	27.04.2016	09:54	12,8	colorless, clear	0,53	0	0	0	0	0	0
160326756	Tank vehicle KWW 35, clutch pipe delivery	27.04.2016	10:25	9,0	colorless, clear	0,52	0	0	0	0	0	0
160326757	Tank vehicle KWW 36, clutch pipe delivery	27.04.2016	09:45	13,8	colorless, clear	0,64	0	0	0	0	0	0
160326758	Tank vehicle KWW 37, clutch pipe delivery	27.04.2016	10:20	9,6	colorless, clear	0,54	0	0	0	0	0	0
160326759	Tank vehicle KWW 38, clutch pipe delivery	27.04.2016	10:35	14,6	colorless, clear	0,76	0	0	0	0	0	0
160326760	Tank vehicle KWW 39, clutch pipe delivery	27.04.2016	09:25	11,2	colorless, clear	0,60	0	0	0	0	0	0
160326789	Tank vehicle KWW 40, clutch pipe delivery	27.04.2016	10:00	12,4	colorless, clear	0,56	0	0	0	0	0	0
160326790	Tank vehicle KWW 41, clutch pipe delivery	27.04.2016	10:15	7,5	colorless, clear	0,45	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500494924
Report April 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160326791	Tank vehicle KWW 42, clutch pipe delivery	27.04.2016	10:10	9,8	colorless, clear	0,47	0	0	0	0	0	0
160326792	Tank vehicle KWW 43, clutch pipe delivery	27.04.2016	09:50	11,6	colorless, clear	0,56	0	0	0	0	0	0
160326793	Tank vehicle KWW 44, clutch pipe delivery	27.04.2016	09:40	11,2	colorless, clear	0,60	0	0	0	0	0	0
160326794	Tank vehicle KWW 45, clutch pipe delivery	27.04.2016	09:32	13,4	colorless, clear	0,66	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, May 04, 2016
