

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report September 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160741248	Drinking water Delivery Tap 1	01.09.2016	09:35	20,6	colorless, clear	0,30	0	0	0	0	0	0
160741249	Drinking water Delivery Tap 2	01.09.2016	09:40	19,6	colorless, clear	0,28	0	0	0	0	0	0
160741250	Drinking water Delivery Tap 3	01.09.2016	09:50	19,8	colorless, clear	0,22	0	0	0	0	0	0
160741451	Drinking water Delivery Tap 4	01.09.2016	09:50	20,6	colorless, clear	0,08	0	0	0	0	0	0
160741452	Tank vehicle KWW 32, clutch pipe delivery	01.09.2016	08:40	22,6	colorless, clear	0,10	0	0	0	0	0	0
160741454	Tank vehicle KWW 34, clutch pipe delivery	01.09.2016	09:05	23,0	colorless, clear	<0,03	0	0	0	0	0	0
160741455	Tank vehicle KWW 35, clutch pipe delivery	01.09.2016	08:30	22,6	colorless, clear	0,12	0	0	0	0	0	0
160741456	Tank vehicle KWW 36, clutch pipe delivery	01.09.2016	08:55	22,0	colorless, clear	0,20	0	0	0	0	0	0
160741457	Tank vehicle KWW 37, clutch pipe delivery	01.09.2016	09:45	23,6	colorless, clear	0,21	0	0	0	0	0	0
160741458	Tank vehicle KWW 38, clutch pipe delivery	01.09.2016	09:00	22,0	colorless, clear	0,26	0	0	0	0	0	0
160741459	Tank vehicle KWW 39, clutch pipe delivery	01.09.2016	09:04	22,4	colorless, clear	0,20	0	0	0	0	0	0
160741460	Tank vehicle KWW 40, clutch pipe delivery	01.09.2016	09:25	22,2	colorless, clear	0,28	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report September 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160741461	Tank vehicle KWW 41, clutch pipe delivery	01.09.2016	08:50	25,0	colorless, clear	<0,03	0	0	0	0	0	0
160741462	Tank vehicle KWW 42, clutch pipe delivery	01.09.2016	09:15	22,2	colorless, clear	0,16	0	0	0	0	0	0
160741463	Tank vehicle KWW 43, clutch pipe delivery	01.09.2016	08:45	21,8	colorless, clear	0,16	0	0	0	0	0	0
160741464	Tank vehicle KWW 44, clutch pipe delivery	01.09.2016	09:20	22,1	colorless, clear	0,20	0	0	0	0	0	0
160741465	Tank vehicle KWW 45, clutch pipe delivery	01.09.2016	09:10	23,6	colorless, clear	<0,03	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, September 09, 2016 \_\_\_\_\_