

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 15.12.2016

Montag, 2. Januar 2017

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-32 clutch pipe delivery	11,4	8,1	0,70	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	12,5	7,9	0,57	0	1	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	13,4	7,9	0,71	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	12,7	7,9	0,84	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	11,3	7,9	0,67	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	12,8	8,1	0,69	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	12,9	7,8	0,80	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	12,7	7,9	0,88	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	12,8	7,8	0,82	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	12,3	8,0	0,76	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	13,4	7,7	0,80	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	12,3	7,7	0,77	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	12,6	7,7	1,08	0	1	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	12,7	7,6	1,02	0	0	0	0	0	0