

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report February 2016

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160098668	Drinking water Delivery Tap 1	12.02.2016	09:45	13,5	colorless, clear	1,03	0	0	0	0	0	0
160098669	Drinking water Delivery Tap 2	12.02.2016	09:50	13,2	colorless, clear	0,80	0	0	0	0	0	0
160098670	Drinking water Delivery Tap 3	12.02.2016	09:55	13,4	colorless, clear	1,03	0	0	0	0	0	0
160098671	Drinking water Delivery Tap 4	12.02.2016	10:00	13,4	colorless, clear	0,98	0	0	0	0	0	0
160098673	Tank vehicle KWW 32, clutch pipe delivery	12.02.2016	09:30	12,2	colorless, clear	0,84	0	0	0	0	0	0
160098674	Tank vehicle KWW 33, clutch pipe delivery	12.02.2016	09:10	8,8	colorless, clear	0,58	0	0	0	0	0	0
160098675	Tank vehicle KWW 34, clutch pipe delivery	12.02.2016	09:00	13,7	colorless, clear	0,61	0	0	0	0	0	0
160098676	Tank vehicle KWW 35, clutch pipe delivery	12.02.2016	08:45	12,3	colorless, clear	0,04	0	0	0	0	0	0
160098677	Tank vehicle KWW 36, clutch pipe delivery	12.02.2016	09:10	11,2	colorless, clear	0,61	0	0	0	0	0	0
160098679	Tank vehicle KWW 38, clutch pipe delivery	12.02.2016	08:50	10,0	colorless, clear	0,04	0	0	0	0	0	0
160098680	Tank vehicle KWW 39, clutch pipe delivery	12.02.2016	09:25	10,2	colorless, clear	0,63	0	0	0	0	50	0
160098681	Tank vehicle KWW 40, clutch pipe delivery	12.02.2016	09:40	12,4	colorless, clear	0,69	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report February 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160098682	Tank vehicle KWW 41, clutch pipe delivery	12.02.2016	09:20	13,7	colorless, clear	0,92	0	0	0	0	0	0
160098683	Tank vehicle KWW 42, clutch pipe delivery	12.02.2016	08:55	15,5	colorless, clear	0,58	0	0	0	0	0	0
160098684	Tank vehicle KWW 43, clutch pipe delivery	12.02.2016	09:00	12,2	colorless, clear	0,48	0	0	0	0	0	0
160098685	Tank vehicle KWW 44, clutch pipe delivery	12.02.2016	09:25	12,4	colorless, clear	0,78	0	0	0	0	0	0
160098686	Tank vehicle KWW 45, clutch pipe delivery	12.02.2016	09:15	11,5	colorless, clear	0,70	0	0	0	0	0	0

Assessment:

According to the investigations of the German Drinking Water Regulation the following parameter of the testing sample 160098680

is out of limit value: **Pseudomonas aeruginosa**

The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, February 17, 2016