

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report January 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
151192764	Drinking water Delivery Tap 1	11.01.2016	09:35	14,2	colorless, clear	0,63	0	0	0	0	1	0
151192765	Drinking water Delivery Tap 2	11.01.2016	09:40	14,8	colorless, clear	0,97	0	0	0	0	0	0
151192766	Drinking water Delivery Tap 3	11.01.2016	09:45	13,7	colorless, clear	0,70	0	0	0	0	0	0
151192767	Drinking water Delivery Tap 4	11.01.2016	09:50	14,0	colorless, clear	0,25	0	0	0	0	0	0
151192768	Tank vehicle KWW 31, clutch pipe delivery	11.01.2016	09:05	14,0	colorless, clear	0,27	0	0	0	0	0	0
151192783	Tank vehicle KWW 32, clutch pipe delivery	11.01.2016	08:50	13,9	colorless, clear	0,59	0	0	0	0	0	0
151192784	Tank vehicle KWW 33, clutch pipe delivery	11.01.2016	09:30	14,3	colorless, clear	0,80	0	0	0	0	0	0
151192785	Tank vehicle KWW 34, clutch pipe delivery	11.01.2016	09:00	13,8	colorless, clear	0,70	0	0	0	0	0	0
151192786	Tank vehicle KWW 35, clutch pipe delivery	11.01.2016	09:20	10,8	colorless, clear	0,76	0	0	0	0	0	0
151192787	Tank vehicle KWW 36, clutch pipe delivery	11.01.2016	09:25	14,0	colorless, clear	0,76	0	0	0	0	0	0
151192789	Tank vehicle KWW 38, clutch pipe delivery	11.01.2016	09:30	13,7	colorless, clear	1,03	0	0	0	0	0	0
151192790	Tank vehicle KWW 39, clutch pipe delivery	11.01.2016	08:50	13,4	colorless, clear	0,57	0	0	0	0	1	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500438981
Report January 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
151192791	Tank vehicle KWW 40, clutch pipe delivery	11.01.2016	08:40	12,1	colorless, clear	0,49	0	0	0	0	0	0
151192792	Tank vehicle KWW 41, clutch pipe delivery	11.01.2016	09:05	14,0	colorless, clear	0,85	0	0	0	0	0	0
151192793	Tank vehicle KWW 42, clutch pipe delivery	11.01.2016	09:15	13,0	colorless, clear	0,57	0	0	0	0	0	0
151192794	Tank vehicle KWW 43, clutch pipe delivery	11.01.2016	08:45	13,5	colorless, clear	0,97	0	0	0	0	0	0
151192795	Tank vehicle KWW 44, clutch pipe delivery	11.01.2016	09:10	12,3	colorless, clear	0,70	0	0	0	0	0	0
151192796	Tank vehicle KWW 45, clutch pipe delivery	11.01.2016	08:55	14,1	colorless, clear	0,78	0	0	0	0	0	0

Assessment:

According to the investigations of the German Drinking Water Regulation the following parameter of the testing samples 151192764 and 151192790 is out of limit value: **Pseudomonas aeruginosa**
The microbiological quality of all other tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, January 14, 2016