

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report July 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160627327	Drinking water Delivery Tap 1	27.07.2016	08:40	22,0	colorless, clear	0,28	0	0	0	0	0	0
160627328	Drinking water Delivery Tap 2	27.07.2016	08:45	22,6	colorless, clear	0,45	0	0	0	0	0	0
160627329	Drinking water Delivery Tap 3	27.07.2016	08:50	21,6	colorless, clear	0,55	0	0	0	0	0	0
160627330	Drinking water Delivery Tap 4	27.07.2016	08:55	22,4	colorless, clear	0,74	0	0	0	0	0	0
160627331	Tank vehicle KWW 32, clutch pipe delivery	27.07.2016	07:55	23,8	colorless, clear	0,45	0	0	0	0	0	0
160627332	Tank vehicle KWW 33, clutch pipe delivery	27.07.2016	08:10	23,4	colorless, clear	-	0	0	0	0	0	0
160627334	Tank vehicle KWW 35, clutch pipe delivery	27.07.2016	08:15	22,4	colorless, clear	-	0	0	0	0	0	0
160627335	Tank vehicle KWW 36, clutch pipe delivery	27.07.2016	08:20	23,2	colorless, clear	-	0	0	0	0	0	0
160627351	Tank vehicle KWW 37, clutch pipe delivery	27.07.2016	07:45	22,8	colorless, clear	0,32	0	0	0	0	0	0
160627352	Tank vehicle KWW 38, clutch pipe delivery	27.07.2016	07:50	23,7	colorless, clear	0,42	0	0	0	0	0	0
160627353	Tank vehicle KWW 39, clutch pipe delivery	27.07.2016	08:05	23,4	colorless, clear	-	0	0	0	0	0	0
160627355	Tank vehicle KWW 41, clutch pipe delivery	27.07.2016	07:45	23,4	colorless, clear	0,41	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report July 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160627356	Tank vehicle KWW 42, clutch pipe delivery	27.07.2016	08:00	22,4	colorless, clear	0,43	0	0	0	0	0	0
160627357	Tank vehicle KWW 43, clutch pipe delivery	27.07.2016	08:35	24,4	colorless, clear	0,31	0	0	0	0	0	0
160627358	Tank vehicle KWW 44, clutch pipe delivery	27.07.2016	08:00	22,4	colorless, clear	0,43	0	0	0	0	0	-
160627359	Tank vehicle KWW 45, clutch pipe delivery	27.07.2016	07:55	22,2	colorless, clear	-	0	0	0	0	0	-

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, August 09, 2016