

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 21.06.2016

Donnerstag, 30. Juni 2016

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-32 clutch pipe delivery	18,8	7,8	0,49	0	0	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	18,7	8,0	0,64	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	19,0	7,8	0,30	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	19,5	8,0	0,17	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	18,5	7,9	0,18	0	2	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	19,0	7,8	0,51	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	19,2	7,7	0,85	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	18,7		0,03	120	192	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	18,8	7,9	0,51	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	19,7	8,1	0,58	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	18,4	8,0	0,59	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	18,3	7,9	0,55	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	19,2	7,7	0,87	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	19,6	7,9	0,80	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	19,2	7,7	1,25	1	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	17,9	7,8	0,49	0	0	0	0	0	0