

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 17.03.2016

Montag, 4. April 2016

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-32 clutch pipe delivery	11,6	7,5	0,69	0	1	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	11,0	7,9	0,45	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	10,1	7,7	0,71	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	9,9	7,6	0,67	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	10,4	7,6	0,69	0	2	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	10,6	7,4	0,73	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	12,3	7,7	0,69	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	10,5	7,7	0,76	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	11,1	7,5	0,81	0	5	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	10,7	7,7	0,67	0	2	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	11,4	7,4	0,72	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	11,0	7,5	0,71	0	2	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	11,3	7,5	0,77	0	3	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	11,7	7,5	0,75	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	11,1	7,4	0,81	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,6	7,4	1,24	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	12,0	7,5	1,46	0	0	0	0	0	0