

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-450049424  
Report May 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160430653	Drinking water Delivery Tap 1	25.05.2016	09:15	18,2	colorless, clear	0,88	0	0	0	0	0	0
160430654	Drinking water Delivery Tap 2	25.05.2016	09:15	17,5	colorless, clear	0,70	0	0	0	0	0	0
160430655	Drinking water Delivery Tap 3	25.05.2016	09:20	17,3	colorless, clear	0,34	0	0	0	0	0	0
160430656	Drinking water Delivery Tap 4	25.05.2016	10:00	18,5	colorless, clear	0,50	0	0	0	0	0	0
160430658	Tank vehicle KWW 33, clutch pipe delivery	25.05.2016	09:00	17,5	colorless, clear	0,34	0	0	0	0	0	0
160430659	Tank vehicle KWW 34, clutch pipe delivery	25.05.2016	09:40	18,0	colorless, clear	0,73	0	0	0	0	0	0
160430660	Tank vehicle KWW 35, clutch pipe delivery	25.05.2016	09:50	17,6	colorless, clear	0,68	0	0	0	0	0	0
160430661	Tank vehicle KWW 36, clutch pipe delivery	25.05.2016	08:55	17,0	colorless, clear	0,34	0	0	0	0	0	0
160430695	Tank vehicle KWW 37, clutch pipe delivery	25.05.2016	08:50	17,3	colorless, clear	0,60	0	0	0	0	0	0
160430696	Tank vehicle KWW 38, clutch pipe delivery	25.05.2016	09:05	17,3	colorless, clear	0,44	0	0	0	0	0	0
160430698	Tank vehicle KWW 40, clutch pipe delivery	25.05.2016	09:10	18,4	colorless, clear	0,80	0	0	0	0	0	0
160430699	Tank vehicle KWW 41, clutch pipe delivery	25.05.2016	09:35	17,8	colorless, clear	0,76	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500494924  
Report May 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
160430700	Tank vehicle KWW 42, clutch pipe delivery	25.05.2016	09:25	16,4	colorless, clear	0,10	0	0	0	0	0	0
160430901	Tank vehicle KWW 43, clutch pipe delivery	25.05.2016	09:20	18,4	colorless, clear	0,84	0	0	0	0	0	0
160430902	Tank vehicle KWW 44, clutch pipe delivery	25.05.2016	09:05	18,0	colorless, clear	0,70	0	0	0	0	0	0
160430903	Tank vehicle KWW 45, clutch pipe delivery	25.05.2016	09:30	16,0	colorless, clear	0,14	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, May 30, 2016

\_\_\_\_\_