

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report October 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
161013842	Drinking water Delivery Tap 1	26.10.2016	10:10	18,4	colorless, clear	1,20	0	0	0	0	0	0
161013843	Drinking water Delivery Tap 2	26.10.2016	09:55	18,0	colorless, clear	1,04	0	0	0	0	0	0
161013844	Drinking water Delivery Tap 3	26.10.2016	09:55	20,0	colorless, clear	1,40	0	0	0	0	0	0
161013845	Drinking water Delivery Tap 4	26.10.2016	09:45	17,4	colorless, clear	1,26	0	0	0	0	0	0
161013846	Tank vehicle KWW 32, clutch pipe delivery	26.10.2016	09:20	16,4	colorless, clear	0,62	0	0	0	0	0	0
161013847	Tank vehicle KWW 33, clutch pipe delivery	26.10.2016	09:15	13,2	colorless, clear	0,56	2	0	0	0	0	0
161013848	Tank vehicle KWW 34, clutch pipe delivery	26.10.2016	09:30	14,8	colorless, clear	0,74	0	0	0	0	0	0
161013849	Tank vehicle KWW 35, clutch pipe delivery	26.10.2016	09:28	13,6	colorless, clear	0,50	0	0	0	0	0	0
161013851	Tank vehicle KWW 37, clutch pipe delivery	26.10.2016	09:10	16,6	colorless, clear	0,84	0	0	0	0	0	0
161013852	Tank vehicle KWW 38, clutch pipe delivery	26.10.2016	09:46	15,0	colorless, clear	0,76	0	0	0	0	0	0
161013853	Tank vehicle KWW 39, clutch pipe delivery	26.10.2016	09:05	16,0	colorless, clear	0,80	0	0	0	0	0	0
161013854	Tank vehicle KWW 40, clutch pipe delivery	26.10.2016	09:08	14,6	colorless, clear	1,10	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report October 2016**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
161013855	Tank vehicle KWW 41, clutch pipe delivery	26.10.2016	09:25	16,2	colorless, clear	0,44	0	0	0	0	0	0
161013856	Tank vehicle KWW 42, clutch pipe delivery	26.10.2016	09:34	14,8	colorless, clear	0,85	0	0	0	0	0	0
161013857	Tank vehicle KWW 43, clutch pipe delivery	26.10.2016	09:00	16,6	colorless, clear	1,00	0	0	0	0	0	0
161013866	Tank vehicle KWW 44, clutch pipe delivery	26.10.2016	09:45	15,0	colorless, clear	0,90	0	0	0	0	0	0
161013867	Tank vehicle KWW 45, clutch pipe delivery	26.10.2016	09:38	15,2	colorless, clear	0,84	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, November 09, 2016 _____