

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 29.09.2016

Freitag, 7. Oktober 2016

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-32 clutch pipe delivery	16,8	7,7	0,70	1	1	0	0	0	0
Tank vehicle KWW-33 clutch pipe delivery	17,9	7,8	0,65	4	2	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	20,5	7,8	0,86	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	19,2	7,8	0,80	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	20,6	7,8	0,73	1	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	19,6	7,9	0,66	0	1	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	19,5	8,1	0,75	0	1	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	19,6	8,2	0,73	0	1	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	20,1	7,9	0,74	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	19,3	8,0	0,73	1	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	19,1	7,9	0,76	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	20,2	7,8	0,87	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	20,3	7,7	1,35	0	1	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	17,9	7,9	0,73	0	1	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	20,9	7,6	0,82	1	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	21,3	7,7	0,78	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	20,6	7,6	0,52	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	20,1	7,7	0,28	0	0	0	0	0	0